


WARNING: RISK OF FIRE AND ELECTRICAL SHOCK. FIXTURE MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN ONLY IN ACCORDANCE WITH NATIONAL, LOCAL BUILDING AND ELECTRICAL CODES. DISCONNECT POWER AT ELECTRICAL PANEL BEFORE SERVICING.


11109-9 INSTALLATION INSTRUCTIONS FOR: 12-Inch Low-Profile Surface-Mount LED Wraparound Light

Safety Precautions:


- **Read Carefully:** Prior to installation or servicing, thoroughly read and understand all safety precautions and instructions. Failure to follow these guidelines may result in serious injury, electric shock, or property damage.
- **Qualified Installation:** It is strongly recommended that all wiring be performed by a licensed electrician. This fixture must be installed in compliance with all national and local electrical codes.
- **Avoid Wet Conditions:** Do not handle or attempt to energize the fixture with wet hands, or while standing on wet surfaces or in water. Do not install within 10 ft or less from the nearest edge of a pool, spa, fountain, or similar location
- **Verify Power Source:** Ensure the power source meets the fixture's requirements.




CAUTION: EDGES MAY BE SHARP: Carefully remove lens from fixture by gently sliding lens over the edge of the fixture one side at a time, and set aside.




Remove driver cover by removing (2) screws. Set aside.




Remove 7/8" knockout from bottom of fixture in desired location to allow for wiring. Bring supply wiring thru and wire in accordance with all national, state and local codes.




Surface mount fixture to desired location by installing appropriate hardware thru key-ways in the pan.




Reinstall the driver cover making sure all wiring is tucked safely under the cover. Test the fixture.




Reinstall the lens by placing the lens over the fixture on one side, then bring the lens over the opposite side.




OPTIONAL-PENDANT MOUNT: Prior to Step 5, remove 1/2" knockout from both ends of fixture.



OPTIONAL-PENDANT MOUNT: Install hanging kits to each end of the fixture. See HC 301/302 instructions for details.



OPTIONAL-PENDANT MOUNT: Reinstall the driver cover making sure all wiring is tucked safely under the cover. Test the fixture.



OPTIONAL-PENDANT MOUNT: Reinstall the lens by placing the lens over the fixture on one side, then bring the lens over the opposite side.